



Burlington, WA *Corporate Laboratory (a)*
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA *Microbiology (b)*
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR *Microbiology/Chemistry (d)*
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
Bend, OR *Microbiology (e)*
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Glenhaven Lakes Club, Inc.

664 Rainbow Dr
Sedro Woolley, WA 98284

Reference Number: 19-41132

Project: Glenhaven Lakes Club Bacteria

System Name: GLENHAVEN LAKES CLUB

System ID Number: 28050V

DOH Source Number: 00 - Distribution Sample (Bacteria)

Sample Type: D - Drinking Water

Sample Purpose: Investigative or Other

Sample Location: Thompson Water Main

County: Whatcom

Sampled By: Dar-Tanion Surratt

Sampler Phone: 360-595-2061

Repeat Sample Number:

Lab Number: 164-79753

Field ID: Glenhaven Lakes

Date Collected: 10/24/19 10:45

Date Received: 10/24/19

Date Set: 10/24/19 17:35

Date Analyzed: 10/25/19 11:59

Report Date: 10/29/19

Comment:

Approved By: ckk,jln

Authorized by:

Ceann K Knox
Lab Manager, Bellingham

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent		per 100mL	jfh	SM9223 B	m_191024	
3	E. COLI	Absent		per 100mL		SM9223 B	m_191024	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>

San Juan Co: <http://www.sanjuan.co/health/ehswater.aspx>

Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380

Snohomish Co: 425-339-5250

Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp

WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.

If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

*If data qualifiers are present, see accompanying Qualifier Definition report.